NRC Publications Archive Archives des publications du CNRC

Basic theory of rapid transit-tunnel ventilation

Brown, W. G.

This publication could be one of several versions: author's original, accepted manuscript or the publisher's version. /
La version de cette publication peut être l'une des suivantes : la version prépublication de l'auteur, la version acceptée du manuscrit ou la version de l'éditeur.

NRC Publications Record / Notice d'Archives des publications de CNRC:

<https://nrc-publications.canada.ca/eng/view/object/?id=a9dc621d-983f-44e0-a72b-9f4e5c5bd419>

<https://publications-cnrc.canada.ca/fra/voir/objet/?id=a9dc621d-983f-44e0-a72b-9f4e5c5bd419>

Access and use of this website and the material on it are subject to the Terms and Conditions set forth at

<https://nrc-publications.canada.ca/eng/copyright>

READ THESE TERMS AND CONDITIONS CAREFULLY BEFORE USING THIS WEBSITE.

L'accès à ce site Web et l'utilisation de son contenu sont assujettis aux conditions présentées dans le site

<https://publications-cnrc.canada.ca/fra/droits>

LISEZ CES CONDITIONS ATTENTIVEMENT AVANT D'UTILISER CE SITE WEB.

Questions? Contact the NRC Publications Archive team at

PublicationsArchive-ArchivesPublications@nrc-cnrc.gc.ca. If you wish to email the authors directly, please see the first page of the publication for their contact information.

Vous avez des questions? Nous pouvons vous aider. Pour communiquer directement avec un auteur, consultez la première page de la revue dans laquelle son article a été publié afin de trouver ses coordonnées. Si vous n'arrivez pas à les repérer, communiquez avec nous à PublicationsArchive-ArchivesPublications@nrc-cnrc.gc.ca.

National Research
Council Canada

Conseil national de
recherches Canada

Canada

Ser
THL
N21r2
no. 273
c. 2

BLDG

27115

ANALYZED

NATIONAL RESEARCH COUNCIL
CANADA

CONSEIL NATIONAL DE RECHERCHES

BASIC THEORY OF RAPID TRANSIT - TUNNEL VENTILATION

BY

W. G. BROWN

A PAPER PRESENTED AT THE
ASME - IEEE RAILROAD CONFERENCE
PITTSBURGH, PA., APRIL 7 - 8, 1965

RESEARCH PAPER NO. 273
OF THE
DIVISION OF BUILDING RESEARCH

OTTAWA

PRICE 25 CENTS

OCTOBER 1965

NRC 8707

THEORIE FONDAMENTALE DE LA VENTILATION DES TUNNELS A CIRCULATION RAPIDE

SOMMAIRE

On a effectué une analyse en vue de déterminer le mécanisme fondamental de la ventilation causée dans un tunnel à circulation rapide par suite de l'action "piston" que produit un train; cette analyse avait également pour but de déterminer les températures qui en résultent dans le système. La théorie concorde généralement avec les résultats des expériences et indique que la vitesse de l'air dans les tunnels est de l'ordre de $1/5$ de la vitesse du train, bien que les trains n'occupent que $1/4$ à $1/3$ de la surface transversale du tunnel. Une petite partie de la charge thermique causée par les trains, les freins, les passagers et la machinerie est absorbée au travers des parois du tunnel, mais le sol sert de réservoir de chaleur: il en résulte que le degré de variation de la température diurne du passage souterrain équivaut approximativement à la moitié de la variation de température de l'air ambiant, ce qui cause un déphasage de plusieurs heures entre les deux. Une théorie en partie empirique alliée à des expériences a permis d'indiquer approximativement les températures auxquelles on peut s'attendre dans un tunnel, dans différentes conditions climatiques. On discute de l'effet d'une programmation de l'horaire des trains sur la vitesse de ventilation et on évalue la possibilité d'employer des modèles en vue d'obtenir des données de calcul plus précises.

an ASME
publication

\$1.00 PER COPY
50¢ TO ASME MEMBERS

The Society shall not be responsible for statements or opinions advanced in papers or in discussion at meetings of the Society or of its Divisions or Sections, or printed in its publications.

Discussion is printed only if the paper is published in an ASME journal.

Released for general publication upon presentation

ANALYZED

Basic Theory of Rapid Transit-Tunnel Ventilation

W. G. BROWN

Research Officer, Building
Services Section, Division of
Building Research, National
Research Council, Ottawa, Canada.

An analysis has been carried out for the basic mechanism of rapid-transit tunnel ventilation due to train piston action and for the temperatures resulting in the system. Theory is in general agreement with experimental results, indicating air velocities in tunnels of the order of $1/5$ of the train velocity even though trains occupy only $1/4$ to $1/3$ of the cross-sectional area of the tunnel. Little of the heat load owing to trains, brakes, passengers and machinery is conducted through the ground about the tunnel, but the ground serves as a heat reservoir causing the amplitude of the diurnal subway temperature variation to be about half that of the ambient air temperature, and causing a phase shift of several hours. With the help of a partly empirical theory combined with experiment it was possible to indicate approximately the temperatures to be expected in a tunnel under differing climate conditions. The effect of train scheduling on ventilation rate is discussed, as is the possibility of using models to obtain more precise design data.

Contributed by the Railroad Division of The American Society of Mechanical Engineers for presentation at the ASME-IEEE Railroad Conference, Pittsburgh, Pa., April 7-8, 1965. Manuscript received at ASME Headquarters, December 21, 1964.

Written discussion on this paper will be accepted up to May 10, 1965.

Copies will be available until February 1, 1966.

Basic Theory of Rapid Transit-Tunnel Ventilation

W. G. BROWN

Until the late 1930's underground railways or rapid-transit systems were generally designed without attention to ventilation, with the result that high temperatures sometimes occurred, necessitating costly construction changes to alleviate passenger discomfort. In the London Underground, for example, Mount (1)¹ reports that a gradual increase over the years in number of passengers, together with heavier trains and greater heat loads, caused continually rising temperatures until, finally, a system of fans had to be installed to bring temperatures to a reasonable level for the comfort of passengers. At the same time, in some stations, passengers and personnel suffered discomfort from very high air velocities in restricted passages at stations and on station platforms.

As another example, Brock (2) reports overheating in the New York Subway and subsequent abandonment of a hurriedly installed refrigeration plant. Rasmus (3), in describing the ventilation of the Chicago Subway, reports that in earlier underground railways steady temperatures of over 90 F were not uncommon in Summer, even when the outside or street level temperatures dropped to the 60's and 70's.

It can be shown easily that in the total absence of ventilation the temperature in a subway would reach perhaps 350 F, owing to a heat load from trains and passengers averaging about 800 Btu/hr per ft of tunnel. Obviously no existing rapid-transit system has temperatures even approaching this order of magnitude. On the other hand many, if not most, of the existing subways experience difficulty at some locations in mid-summer although at other locations the ventilation is more than sufficient to maintain reasonable temperatures.

The Chicago Subway appears to have been the first for which a rational analysis was attempted, before construction, of both the ventilating effect of train piston action and the heat load from motors, passengers and lighting to be dissipated. This analysis was carried out by Brock (2), who developed equations for the piston effect based on steady-state assumptions and considered the heat-storage capacity of the ground in dissipating the heat load. It will be shown in the present paper that steady-state assumptions are inadequate for

the description of underground railway ventilation. (As far as is known the nonsteady-state procedure to be used here has not been applied previously to underground railways.) Nevertheless, the work done in connection with the Chicago Subway resulted in recognition of most of the factors involved. The information obtained from this study, combined with experience gained in earlier subway systems led to a generally adequate ventilation system for the Chicago Subway, as was evident in follow-up measurements of actual air flow rates and temperatures, Rasmus and Brock (4). Experience with the Chicago Subway was then relied upon heavily, some ten years later, and in the design of the Yonge Street section of the Toronto Rapid Transit System.

Although recent subways can generally be described as "adequate" from a ventilation and temperature standpoint, they are so few in number as to give essentially no indication of whether improved design is possible. It is not clear, for example, whether construction economies may be possible or whether temperature and comfort conditions can be improved perhaps by simple changes in the aerodynamic characteristics of trains, tunnels, and ventilation openings from tunnels to the street, or even by small changes in train scheduling.

By way of general orientation, Fig.1 shows a typical double-track underground railway section drawn approximately to scale. In traversing the tunnel, trains force air ahead of themselves and out ventilation shafts and passenger exits, drawing air into the tunnel through similar openings behind them. Vent (or blast) shafts at the ends of stations serve the two-fold purpose of providing ventilation and reducing air velocities over the platform area in order to maintain reasonable comfort. Fans, primarily for emergency use, are usually installed in fan shafts between stations. With fans inoperative the shafts serve simply as ventilation outlets.

The heat generated by train drives, passengers and lighting is removed by ventilation air; the result is an average subway temperature higher than the average ambient temperature by an amount depending on the ventilation rate. Only a small fraction of the heat generated is conducted through the ground above the subway, but the ground does serve as a heat reservoir and has the effect of partially damping temperature fluctuations generated by the diurnal and annual ambient air cycles.

¹ Underlined numbers in parentheses designate References at the end of the paper.

Fig.1 Typical underground rapid-transit construction (double track).
 (a) plan view; (b) tunnel section, including ventilation shafts;
 (c) station section, showing platform

Fig.2 (a) Schematic representation of a train in a single length of tunnel

Fig.2 (b) Air velocities as observed from the train

The subject matter of underground railway ventilation divides itself naturally into the two separate components of air-flow rates and the temperatures that result. It is the purpose of this paper to carry development of the theory to its practical limit and to indicate the applicability of other methods for obtaining final design information.

MECHANISM OF TRAIN PISTON ACTION

Although the situation will seldom arise in actual practice, the analysis will first be confined to the simple case of a tunnel without openings, but discharging freely into the atmosphere at both ends, Fig.2(a). A train of length l travels at velocity U in a tunnel of length L .

With air flowing to the right with velocity v , a momentum balance gives

$$p_a = f \frac{x}{d} \frac{v^2}{2g} + \frac{x}{g} \frac{dv}{dt} \quad (1)$$

and

$$p_b = -f \frac{(L-l-x)}{d} \frac{v^2}{2g} - K_e \frac{v^2}{2g} - \frac{v^2}{2g} - \frac{(L-l-x)}{g} \frac{dv}{dt} \quad (2)$$

or

$$p_a - p_b = s_1 \left[f \frac{(L-l)}{d} + 1 + K_e \right] \frac{v^2}{2g} + \frac{(L-l)}{g} \frac{dv}{dt} \quad (3)$$

where p_a and p_b are the static pressures ahead of and behind the train, f is Darcy's friction factor, d is the hydraulic diameter of the tunnel and K_e

is the pressure loss coefficient at tunnel entrance. s_1 is the sign of v . It has been included in equation (3) because v and the friction may both be negative when trains travel in both directions.

Considering, now, the train to be at rest and the tunnel walls and air to be in motion to the left, as in Fig.2(b), we have

$$p_a - p_b - (K_c + K_x) \frac{v_i^2}{2g} - F_i - \frac{\ell}{g} \frac{dv_i}{dt} = 0 \quad (4)$$

Here v_i is the apparent velocity of air beside the train, as viewed from the train, and K_c and K_x are contraction and expansion pressure loss coefficients. The subscript i refers to conditions between the train and tunnel. The friction pressure loss F_i is positive or negative depending upon the relative magnitudes of v_i and U . A simple expression for F_i is obtained with the approximation

$$F_i = f_t \frac{\ell H}{4WH} \frac{v_i^2}{2g} - f_w s_2 \ell \frac{(2W + H)}{4WH} \frac{(U - v_i)^2}{2g} \quad (5)$$

Here, the frictional drag along the wall, ceiling and floor (subscript w) is subtracted from the friction along the side of the train (subscript t). W is the width of opening between the train and the wall and H is tunnel height. s_2 is the sign of $(U - v_i)$. The hydraulic diameters of the train side and remaining surfaces are $4WH/H$ and $4WH/(2W + H)$, respectively.

Assuming for simplicity that $f_t \approx f_w = f$, equation (5) becomes

$$F_i = \frac{f \ell}{4WH} \frac{v_i^2}{2g} \left\{ H - s_2 (2W + H) \left(\frac{U}{v_i} - 1 \right)^2 \right\} \quad (6)$$

It will also be noted that

$$v_i = (U - v) A / WH \quad (7)$$

where A is the tunnel cross-sectional area, and

$$\frac{dv_i}{dt} = - \frac{A}{WH} \frac{dv}{dt} \quad (8)$$

Substituting equations (6) and (8) into equation (4) and equating (4) to (3) now yields

$$\begin{aligned} s_1 \left[f \frac{(L - \ell)}{d} + 1 + K_e \right] \frac{v^2}{2} + (L - \ell) \frac{dv}{dt} \\ = \frac{1}{2} \left[K_c + K_x + \frac{f \ell}{4WH} \left\{ H - s_2 (2W + H) \left(\frac{U}{(U - v) \frac{A}{WH}} - 1 \right)^2 \right\} \right] \times \left(\frac{U}{(U - v) \frac{A}{WH}} - 1 \right)^2 \frac{A}{WH} \cdot \frac{dv}{dt} \end{aligned} \quad (9)$$

Equation (9) can be rearranged into the dimensionless form

$$\frac{dv^*}{a + bv^* + cv^{*2}} = -dt^* \quad (10)$$

where $v^* = v/U$, $t^* = t/\tau$ (τ is a characteristic time, e.g., the train headway), and

$$a = \frac{\tau U}{\ell \left(\frac{A}{WH} + \frac{L}{\ell} - 1 \right)} \left[\left\{ \frac{s_2 (2W + H) f \ell}{8A} \right\} \left\{ 1 - \frac{2A}{WH} + \frac{A^2}{W^2 H^2} \right\} - \frac{A}{2WH} \left\{ K_c + K_x + \frac{f \ell}{4W} \right\} \right]$$

$$b = \frac{\tau U}{\ell \left(\frac{A}{WH} + \frac{L}{\ell} - 1 \right)} \cdot \frac{A}{WH} \left[\left\{ K_c + K_x + \frac{f \ell}{4W} \right\} - \frac{s_2 (2W + H) f \ell}{4} \left\{ \frac{1}{WH} - \frac{1}{A} \right\} \right]$$

$$c = \frac{\tau U}{\ell \left(\frac{A}{WH} + \frac{L}{\ell} - 1 \right)} \cdot \frac{WH}{A} \left[s_1 \left\{ f \frac{(L - \ell)}{8A} P + \frac{(1 + K_e)}{2} \right\} - \frac{A^2}{2W^2 H^2} \left\{ K_c + K_x + \frac{f \ell}{4W} \right\} + \frac{s_2 (2W + H) A^2 f \ell}{8 W^3 H^3} \right]$$

Here P is the tunnel perimeter.

There are two solutions to equation (10), depending upon whether $q = 4ac - b^2$ is positive or negative. These are

$$\frac{1}{\sqrt{q}} \ln \left[\frac{2cv^* + b - \sqrt{-q}}{2cv^* + b + \sqrt{-q}} \right] = C - t^* \quad (11)$$

$$\frac{2}{\sqrt{q}} \tan^{-1} \frac{(2cv^* + b)}{\sqrt{q}} = C - t^* \quad (12)$$

After the train leaves the tunnel the velocity conditions are defined by equation (3) with $p_a - p_b = 0$ and with $(L - \ell)$ replaced by L ; thus

$$\frac{\tau U}{L} \cdot \frac{s_1}{2} \left[\frac{fLP}{4A} + 1 + K_e \right] v^{*2} = -dt^* \quad (13)$$

or

$$\frac{1}{\frac{\tau U}{L} \cdot \frac{s_1}{2} \left[\frac{fLP}{4A} + 1 + K_e \right] v^*} = c + t^* \quad (14)$$

From hydraulic experiments it is known that

Fig. 3 Tunnel air velocities for a single traverse of trains of different lengths in tunnels of different lengths; train velocity = 3090 fpm (35 mph); L = tunnel length; l = train length

$$K_e = 0.5 \text{ (for square-edged entry into the tunnel)}$$

$$K_c \approx 0.5 \left[1 - \frac{WH}{A} \right] \text{ (contraction over front of train)}$$

$$K_x = \left[1 - \frac{WH}{A} \right]^2 \text{ (expansion over rear of train)}$$

$$f \approx 0.03$$

The ventilation induced by trains for various values of L , l , W , H and A can now be evaluated. Generally, the cross-sectional area of trains will be constant at about 100 sq ft, hence $WH = (A - 100)$ sq ft. A standard train stands 12 ft high and requires 11 ft width for clearance; consequently the minimum possible area of a double-track tunnel is about 300 sq ft. (For the Toronto Rapid Transit System, $A = 358$ sq ft.) The length of newer subway cars is 75 ft, and usually a minimum of 3 or 4 cars (train length = 225 to 300 ft) constitutes a train. The maximum train length is governed by the length of station platforms (about 500 ft). The train headway, or frequency of trains in each direction, varies from about $2\frac{1}{4}$ min during rush hours to 6 min for night-time operation. Normal daytime operation generally requires a headway of about $3\frac{1}{2}$ to 4 min. Trains usually move at 30 to 40 mph in traversing a tunnel section. (For the following examples a train speed of 35 mph is assumed.)

VENTILATION PRODUCED BY SINGLE TRAINS

Using the foregoing equations and data and with $A = 358$ sq ft, examples are given in Fig. 3 of

Fig. 4 Two examples of two-way traffic in a 2500-ft tunnel; (train length = 500 ft, train headway = 3.67 min). (a) Train enters tunnel from left; (b) train leaves tunnel at right; (c) train enters tunnel from right; (d) train leaves tunnel at left

the air velocity in tunnels of different lengths for two conditions of train length, the train making only a single pass through the tunnel. It will be seen that the maximum air velocity attained as the train leaves the tunnel is approximately the same, irrespective of tunnel length. For trains of 250 ft and 500 ft length the maximum velocities obtained are about 0.16 and 0.20 of the train velocity. The total ventilation obtained does not vary greatly with tunnel length.

The foregoing results correspond to railway tunnels rather than to rapid-transit systems because of the large differences in train frequency between the two systems. Earlier methods of evaluating the ventilation rates for both railway and rapid-transit systems contain serious errors by neglecting time dependence (2); this is equivalent to having trains follow one another into the tunnel indefinitely at short intervals of time. Although this concept is inapplicable for trains, it is appropriate for heavily travelled automobile tunnels (5).

VENTILATION PRODUCED BY TRAINS MOVING IN BOTH DIRECTIONS AT UNIFORM TIME INTERVALS

With trains moving in both directions in the tunnel, both the frequency (headway) and position when passing obviously will affect the net ventilation rate. For example, little ventilation is produced if trains enter both ends of the tunnel simultaneously, whereas maximum ventilation occurs

Fig.5 Measured air velocities in a vent shaft of a rapid-transit system (north-east vent shaft, College Street Station, Toronto Rapid-Transit System)

if they pass one another outside the tunnel. Between these two extremes the ventilation may have any value depending on the train scheduling. Two examples of velocity distribution, as dependent on train scheduling, are given in Fig.4. These have been calculated with the help of the previous equations, based on a train length of 500 ft, tunnel length of 2500 ft and with train headway of 3.67 min (normal daytime headway in the Toronto Rapid Transit System). Account was taken of the perforated center wall by assuming its only effect to be an increase in perimeter P by the amount $2H$ in parameter c and in equations (11), (12) and (14). In one case a train enters the tunnel just as the train from the opposite direction leaves and results in a net through-flow of air in one direction along the tunnel. In the second example there is no net airflow through the tunnel, the trains being scheduled to enter the tunnel at time intervals of one half of the headway.

For purposes of comparison an example of velocities measured in a vent shaft of the Toronto Rapid Transit System is given in Fig.5. It is not to be implied that the calculated results in Fig.4 are in agreement with those of Fig.5, but only that the general behavior and magnitudes are similar. The differences in shape and magnitude of the velocity profiles are due to the complex sys-

tem of tunnel and openings in the actual subway.

Fig.4 indicates average air velocities in the tunnel of about 200 to 300 fpm, corresponding to flow rates in the tunnel of 70,000 to 100,000 cfm. The average velocity range for the vent shaft in Fig.5 is about the same as that in Fig.4, but the shaft cross-sectional area is 217 sq ft (compared with the tunnel cross section of 384 sq ft).

DESIGN METHODS FOR TUNNELS WITH VENTILATION SHAFTS AND OPENINGS

The foregoing considerations have shown the general magnitude of the ventilation that can be expected in tunnels without openings. The analysis cannot be considered to be exact because friction and pressure-loss coefficients were estimated from similar hydraulic situations. Considerable difficulty arises even in attempting to account for the perforated center wall of a double-track system. In actual fact, the air moving ahead of and behind the train would require a distance of several hundred feet before its velocity would be uniform on both sides of the center wall.

In an actual subway there are passenger openings at stations and ventilation shafts at intervals along the tunnel. These openings in no way can be considered as demarking separate lengths of tunnel requiring only the previous method of analysis. Rather, the openings separate the airflow, some of the air leaving through the opening and the remainder continuing in the tunnel. The resistance to air flow through both branches at such a juncture depends not only on the geometry of the construction, but also on the ratio of the velocity in the branch to that upstream of the branch. It must be emphasized that these resistances can only be obtained by experiment either in the field or on scale models.

Equations can be derived for the situation of multiple openings by the same process used in obtaining equations (11) and (14). The result, however, is a set of simultaneous nonlinear differential equations with nonconstant coefficients. The only practical way to solve these would be with the help of an analog computer, whose facilities could handle at most only 3 or 4 tunnel openings. As geometrical models of the various openings are required to obtain friction coefficients, it is only a small step further to consider a complete model of a subway section. Resort to models is not necessary, of course, in planning conventional subways in moderate climates; it is only necessary to design on the basis of past experience. For special conditions such as in warm climates or where novel ventilation schemes are pro-

posed, the method of models may prove useful in evaluating a system prior to actual construction. Models will be discussed later in connection with subway temperatures.

HEAT BALANCE AND SUBWAY AIR TEMPERATURE

In the following development a simplified and partly empirical procedure will be used that will indicate the mechanism by which heat is exchanged and allow approximate calculation of subway air temperature. (In this connection it should be pointed out that the full theory presents no essential mathematical difficulties, but is sufficiently complex that its development is unwarranted for the present purposes.) Perfect mixing of the air in the tunnel will be assumed. It then becomes immaterial whether the air exchange takes place by alternate injection and ejection through ventilation openings or by continuous injection at one location and ejection at another. Under this condition the tunnel air temperature is everywhere equal.

It will be appreciated that the foregoing assumption places severe restrictions on relating the ventilation rates to the resulting temperatures. Consequently, in the following derivations empirical coefficients will be attached to the simplified theory to account for deviations. To obtain these coefficients the temperatures measured in an actual station will be related to average ventilation rates and heat loads for both tunnel and station.

In a length of underground railway whose total volume is V and whose surface area is A_s , the heat entering the tunnel by ventilation (when the outside air temperature is higher than the tunnel air temperature) and from trains and passengers is absorbed into the ground surrounding the tunnel and by the air (in the tunnel), which then changes temperature. This heat balance may be written as:

$$\rho c_p E_1 Q (T_O - T_i) + E_2 q_L L = q_G A_s + \rho c_p V \frac{dT_i}{dt} \quad (15)$$

where

- ρc_p = specific heat per unit volume of air
- E_1 = ratio of apparent ventilation in a station to average for station plus tunnel
- E_2 = ratio of apparent heat load in a station to average for station plus tunnel
- Q = ventilation rate (average for station plus tunnel)
- T_O, T_i = outside air and tunnel air temperatures, respectively

tures, respectively

q_L = heat load on the subway from trains, passengers, lighting and machinery (L is tunnel length)

q_G = heat flowing into the ground

$\frac{dT_i}{dt}$ = rate of change of tunnel air temperature with time

Temperature Variation

The ambient air temperature is assumed to be expressed, approximately, by

$$T_O = \bar{T}_O + C_A \sin(w_A t + e_A) + C_D \sin(w_D t + e_D) \quad (16)$$

and the subway air temperature by

$$T_i = \bar{T}_i + B_A \sin w_A t + B_D \sin w_D t \quad (17)$$

where $\bar{T}_O, \bar{T}_i$ are the mean annual values of the ambient and tunnel air temperatures, C is the amplitude of variation of ambient air temperature, and B is the amplitude of tunnel air temperature variation. Subscript A denotes annual, and D denotes daily conditions.

$w = 2\pi/\gamma$, where γ is the period

$$(\gamma_D = 24 \text{ hours}, \gamma_A = 365 \times 24 \text{ hours})$$

t is time and e is the phase shift.

With the subway air temperature varying sinusoidally, the following expression is available for the heat flow into the ground about the tunnel (6 pages 65-67):

$$q_G = k_G \left[B_A \sqrt{\frac{w_A}{2a}} (\sin w_A t + \cos w_A t) + B_D \sqrt{\frac{w_D}{2a}} (\sin w_D t + \cos w_D t) + S (\bar{T}_i - T_O) \right] \quad (18)$$

Here k_G is the ground thermal conductivity, a its diffusivity, and S the shape factor for conduction from the tunnel to the ground above. (Tunnel wall and air temperatures are assumed equal.)

Equation (18) assumes all cyclical heat flow to be perpendicular to walls, ceiling and floor and is approximate in that it does not account for distortion at corners. Furthermore, if the tunnel ceiling is less than about 10 to 15 ft deep, the equation must be altered to account for the fact that the depth is finite (for the calculation method in this case (reference 6, page 110)).

After substituting equations (16), (17) and (18) into equation (15), expanding $\sin(wt + e)$, equating the coefficients of $\sin wt$ and of $\cos wt$, the following identities are obtained:

$$\bar{T}_i - \bar{T}_o = E_1 q_L (\rho c_p E_2 Q/L + k_G S) \quad (19)$$

$$B = \frac{m C \cos e}{1+m} = \frac{m C \sin e}{1+n} \quad (20)$$

and

$$e = \tan^{-1} \frac{(1+n)}{(1+m)} \quad (21)$$

where

$$m = \frac{\rho c_p E_2 Q}{k_G A_S} \sqrt{\frac{2\alpha}{w}} \quad (22)$$

and

$$n = \frac{c_p V}{k_G A_S} \sqrt{2\alpha w} \quad (23)$$

Because the geometry of underground tunnels will not usually vary greatly, the foregoing relationships may be simplified by substituting representative values for all variables except q_L , Q , E_1 , E_2 . Furthermore, the variables for stations and tunnel are nearly the same; hence, only station conditions will be considered, these being the more important. The following values are assumed:

$$w_D = 0.262 \text{ hr}^{-1}$$

$$w_A = 0.000718 \text{ hr}^{-1}$$

$$\rho = 0.075 \text{ lb/ft}^3$$

$$k_G = 0.6 \text{ Btu/hr} \cdot ^\circ\text{F} \cdot \text{ft}$$

$$\alpha = 0.02 \text{ ft}^2/\text{hr}$$

System

$$q_L = 800 \text{ Btu/hr} \cdot \text{ft}$$

Equations(19), (22), (23) now become

$$\bar{T}_i - \bar{T}_o = 800 E_1 (3.6 \times 10^{-5} E_2 Q + 3.6) \quad (19a)$$

$$m_D = 1.65 \times 10^{-7} E_2 Q \quad (22a)$$

$$m_A = 3.15 \times 10^{-6} E_1 Q$$

$$n_D = 0.134$$

$$n_A = 7.0 \times 10^{-3} \quad (23a)$$

With the foregoing substitutions the equation for the subway temperature becomes

$$\begin{aligned} T_i = T_o + & \frac{800 E_1}{3.6 \times 10^{-5} E_2 Q + 3.6} \\ & + \frac{3.15 \times 10^{-6} E_2 Q C_A \sin(7.18 \times 10^{-4} t)}{\sqrt{(1.007)^2 + (1 + 3.15 \times 10^{-6} E_2 Q)^2}} \\ & + \frac{1.65 \times 10^{-7} E_2 Q C_D \sin(0.262 t)}{\sqrt{(1.134)^2 + (1 + 1.65 \times 10^{-7} E_2 Q)^2}} \end{aligned} \quad (24)$$

In order to eliminate, as much as possible, errors due to deviation of the annual ambient temperature variation from a sine wave, substitution is made for $\bar{T}_o$ from equation (16). Thus

$$\begin{aligned} T_i - T_o = & \frac{800 E_1}{(3.6 \times 10^{-5} E_2 Q + 3.6)} \\ & + C_A \left[\frac{3.15 \times 10^{-6} E_2 Q \sin(7.18 \times 10^{-4} t)}{\sqrt{(1.007)^2 + (1 + 3.15 \times 10^{-6} E_2 Q)^2}} - \sin(7.18 \times 10^{-4} t + e_A) \right] \\ & + C_D \left[\frac{1.65 \times 10^{-7} E_2 Q \sin(0.262 t)}{\sqrt{(1.134)^2 + (1 + 1.65 \times 10^{-7} E_2 Q)^2}} - \sin(0.262 t + e_D) \right] \end{aligned} \quad (25)$$

Data for Toronto
Rapid Transit

$V = 310,000 \text{ cu ft for a station 500 ft long}$
 $A_s = 61,000 \text{ sq ft for a station 500 ft long}$
 $S = 6.0 \text{ for a station section}$

Comparison with Measured Temperatures

Fig.6 gives measured temperatures for the first three weeks in October in a station of the Toronto Rapid Transit System. To be noted is the uniformity of weekly behavior compared with the variability of the ambient air temperature, Fig.7.

Fig. 6 Air temperatures in the College Street Station, Toronto Rapid-Transit System, October 1962

Fig. 7 Ambient air temperature (Bloor Street Meteorological Office, Toronto) October 1962

Table 1 Data for Calculation of Subway Temperatures Station Section (L = 500ft)

TABLE 1

DATA FOR CALCULATION OF SUBWAY TEMPERATURES
STATION SECTION (L = 500ft)

Ventilation rate $\frac{Q}{\text{Cu ft/hr}}$	$\bar{T}_i - \bar{T}_o (^{\circ}\text{F})$			Annual Amplitude (F deg)	Diurnal Amplitude (F deg)
	$q_L = 400$	$q_L = 800$	$q_L = 1200$		
2.5×10^5	48	97	165	$0.68 C_A$	$0.08 C_D$
5×10^5	25	51	77	$0.82 C_A$	$0.15 C_D$
1.5×10^6	9	18	27	$0.93 C_A$	$0.36 C_D$
2.5×10^6	5	11	16	$0.96 C_A$	$0.50 C_D$
5×10^6	3	5	8	$0.98 C_A$	$0.68 C_D$
00	0	0	0	$1.0 C_A$	$1.0 C_D$

Example: $Q = 1.5 \times 10^6$ cu ft/hr, $q_L = 800$ Btu/hr-ft

$$\bar{T}_o = 50^{\circ}\text{F}, C_A = 20^{\circ}\text{F deg}, C_D = 8^{\circ}\text{F deg}$$

$$\begin{aligned} T_i (\text{maximum}) &= 50 + (18 + 20 \times 0.93 + 8 \times 0.36) \\ &= 89.5^{\circ}\text{F} \end{aligned}$$

Fig. 8 Average air temperatures for weekday operation, Toronto Rapid-Transit System

This particular section of subway had a measured ventilation rate of 2,400,000 cfm during normal daytime operation, Monday to Friday. An estimate of the factors E_1 and E_2 can now be obtained by comparing the average subway and ambient air temperatures. It will be noted that some of the records are missing from Fig. 6; hence temperatures were averaged only for Wednesday, Thursday and Friday of the three-week period. These average results are given in Fig. 8, from which the mean daily subway air temperature, Wednesday to Friday, is 70.9 F, while the average outside air temperature is 59.7 F. The station temperature thus averages 11.2 deg F higher than the ambient air temperature. The amplitude of the diurnal station temperature wave (half the difference between maximum and minimum temperature) is 2.7 degrees F and the ambient air temperature amplitude is 5.5 degrees F.

The coefficient of $\sin(0.262t)$ in equation

(24) is the amplitude of the diurnal subway air-temperature wave. Equating this to the observed value of 2.7 deg F for $Q = 2,400,000$ gives a value for E_2 of 3.1. (The fact that this value is so high should not be cause for concern as it represents only empirical incorporation of the various theoretical approximations.) The corresponding value of e_D is 0.47 radians, corresponding to a lag of 1.8 hr behind the ambient air cycle. From Fig. 8 the observed lag is about 2.5 hr. With E_2 established it will be found that e_A is only 0.035 radian; i.e. the subway air temperature lags behind the annual outside air temperature cycle by only about two days. As it turns out, the second term in equation (25) is negligible for the October period in the Toronto Rapid Transit System, so that the first term represents the mean annual difference in temperature between the outside air and the subway. Setting $\bar{T}_1 - \bar{T}_0 = 11.2$ deg F, the value for E_1 is found to be 3.8.

Maximum Subway Temperatures Attained in Midsummer

With the help of the figures obtained, the approximate temperatures as they would occur in any climate can now be estimated. In Table 1 are given the mean annual differences in temperature between subway air and ambient air for different values of q_L , and the diurnal and annual subway air-temperature amplitude in terms of the ambient amplitude for various values of Q . Values for T_O , C_A and C_D can be obtained from meteorological records. The value $q_L = 800$ Btu/hr-ft is the present load on the Toronto, Yonge Street, Rapid Transit System, $q_L = 1200$ Btu/hr-ft is a possible future load, and $q_L = 400$ Btu/hr-ft has been suggested as the possible load for trains with regenerative rather than rheostatic brakes.

DISCUSSION AND CONCLUSION

The analysis of subway temperatures has shown that in steady operation the ventilation rate determines not only maximal temperatures reached in summer, but also the amplitude of variation of the daily temperature and the annual temperature wave. By a simple comparison with measured temperatures and ventilation rates it has been found possible to estimate temperatures for other climates and for other ventilation rates. The estimates would apply, of course, only to tunnels similar to that investigated. The data given in Table 1 should be treated with considerable caution, and are intended principally for approximations in the absence of more definitive information. In actual fact, the temperature in a tunnel varies from point to point, being close to ambient air temperature near ventilation openings and passenger exits. In addition, the various sections of a tunnel have both reciprocating air flow and some flow in one direction. Under these conditions there is a tendency for the location of the highest temperatures to be displaced in the direction of net flow.

Analysis has shown that very little heat is conducted away into the ground about the subway. The ground does serve as a partial heat reservoir, however, during the diurnal temperature cycle, as it reduces the amplitude of the temperature wave and causes the subway temperature to be about 2.5 hr out of phase with the ambient temperature. The ground serves only as a weak heat reservoir with regard to the annual temperature wave, the phase shift being about two days.

There has been some speculation that the temperatures in a subway system will tend to rise over the years, even in the absence of an increase in heat load. A simple calculation shows, however,

that less than one year is required for the steady periodic state to be reached.

It should be possible to evaluate temperatures more accurately by employing the full theory. Considerable time would be required to make the calculations, however, and a detailed knowledge of the flow characteristics in the tunnel and exits should first be available for this purpose. In this connection it would probably prove simpler, for special situations, to build a heated model at a scale of perhaps 1:20; temperatures could then be obtained by measurement rather than calculation. As the principal component of the temperature is that which would occur with constant ambient air temperature, the model could be operated with this condition. Such a model could be built of sheet metal and used simultaneously to determine velocity conditions in passenger areas and also indicate necessary design alterations prior to construction.

An analysis of the ventilating effect of trains in tunnels that takes account of the inertia of the air has shown that tunnel air velocities up to 1/5 of the train velocity occur even though the train cross-sectional area may be only 1/4 to 1/3 of the tunnel cross-section. Both the train frequency (headway) and train scheduling (as it establishes locations where trains from opposite directions meet) affect the ventilation rates of the tunnel system. The ventilation rate in tunnels without intermediate openings is not strongly affected by train length or by moderate differences in frictional resistance and drag.

Apart from the obvious methods of assuring maximum ventilation in tunnels by minimizing the flow resistance in openings, the behavior of tunnel systems having ventilation openings and stations at intervals along the length proves to be extraordinarily complex. For this case very little precise information about ventilation can be obtained analytically, and for special situations only the method of models can be expected to give reasonably precise design information. In this connection it might be pointed out that model tests have been carried out recently in connection with automobile tunnels (2,7,8), but to the author's knowledge no work of this kind has been done for rapid-transit systems. When it is recalled that the cost of subway construction is comparable to that of aircraft design, where models are used extensively, the same method could bear consideration for subways.

ACKNOWLEDGMENT

The author is greatly indebted to Messrs. W. H. Paterson, General Manager, J. T. Harvey, Chief Engineer, and F. C. Pattie, Mechanical Engineer,

of the Subway Construction Branch, Toronto Transit Commission, for their assistance with problems and data pertaining to subway ventilation. This paper is a contribution from the Division of Building Research of the National Research Council, Canada, and is published with the approval of the Director of the Division.

REFERENCES

- 1 S. C. Mount, "Ventilation and Cooling in London's Tube Railways," Institution of Heating and Ventilating Engineers Journal, January-February 1947, pp. 354-374, 403.
- 2 E. Brock, "Development of Formulae for Calculating Ventilation for the Chicago Subways," Journal of the Western Society of Engineers, vol. 48, no. 2, June 1943, pp. 76-91.
- 3 W. E. Rasmus, "Ventilating the New Chicago Subway," Heating, Piping and Air Conditioning, vol. 15, no. 8, August 1943, pp. 393-399.
- 4 W. E. Rasmus and E. Brock, "Train Piston Action Ventilation and Atmospheric Conditions in Chicago Subways," Trans. ASME, vol. 50, 1944, pp. 385-404.
- 5 A. Haerter, "Theoretische and experimentelle Untersuchungen über die Lüftungsanlagen von Strassentunneln," Dissertation No. 3024, Swiss Federal Institute of Technology, Zurich 1961.
- 6 H. S. Carslaw and J. C. Jaeger, "Conduction of Heat in Solids," 2nd edition, Clarendon Press, 1959.
- 7 A. L. Oliver and H. C. Gurner, "Water Model Tests on Road Tunnel Ventilation," DSIR, Glasgow, Fluids Report no. 49, 1956.
- 8 L. H. Butlet, "Laboratory Air-model Tests on Road-tunnel Ventilation," DSIR, Glasgow, Fluids Report no. 64, 1958.