NRC Publications Archive Archives des publications du CNRC

Spiral ground heat exchangers for heat pump applications Svec, O. J.

This publication could be one of several versions: author's original, accepted manuscript or the publisher's version. /
La version de cette publication peut être l'une des suivantes : la version prépublication de l'auteur, la version
acceptée du manuscrit ou la version de l'éditeur.

Publisher's version / Version de l'éditeur:

*Proceedings of the 3rd International Energy Agency Heat Pump Conference, pp.
443-453, 1990-03-12*

NRC Publications Archive Record / Notice des Archives des publications du CNRC :
<https://nrc-publications.canada.ca/eng/view/object/?id=d9e93bc8-26c7-4a22-842e-0c5c178b0eca>
<https://publications-cnrc.canada.ca/fra/voir/objet/?id=d9e93bc8-26c7-4a22-842e-0c5c178b0eca>

Access and use of this website and the material on it are subject to the Terms and Conditions set forth at
<https://nrc-publications.canada.ca/eng/copyright>

READ THESE TERMS AND CONDITIONS CAREFULLY BEFORE USING THIS WEBSITE.

L'accès à ce site Web et l'utilisation de son contenu sont assujettis aux conditions présentées dans le site
<https://publications-cnrc.canada.ca/fra/droits>

LISEZ CES CONDITIONS ATTENTIVEMENT AVANT D'UTILISER CE SITE WEB.

Questions? Contact the NRC Publications Archive team at
PublicationsArchive-ArchivesPublications@nrc-cnrc.gc.ca. If you wish to email the authors directly, please see the
first page of the publication for their contact information.

Vous avez des questions? Nous pouvons vous aider. Pour communiquer directement avec un auteur, consultez la
première page de la revue dans laquelle son article a été publié afin de trouver ses coordonnées. Si vous n'arrivez
pas à les repérer, communiquez avec nous à PublicationsArchive-ArchivesPublications@nrc-cnrc.gc.ca.

Ref
Ser
TH1

N21d
n. 1685
1990
BLDG.

**National Research
Council Canada**

Institute for
Research in
Construction

**Conseil national
de recherches Canada**

Institut de
recherche en
construction

IRC PUB

Spiral Ground Heat Exchangers for Heat Pump Applications

by Otto J. Svec

ANALYZED

Reprinted from
Proceedings of the 3rd International Energy Agency
Heat Pump Conference, Tokyo, Japan
12-15 March, 1990
pp. 443-453
(IRC Paper No. 1685)

NRCC 32355

NRC - CISTI
IRC
LIBRARY

APR 25 1991

BIBLIOTHÈQUE
IRC
CNRC - ICIST

Canada

105/9605

Résumé

Ce document décrit un nouveau système horizontal d'échange de chaleur sur sol utilisé dans une installation expérimentale de pompe à chaleur à captage au sol (PCCS). Le principe consiste à activer une grande masse de sol en employant de gros échangeurs de chaleur à spirale (pouvant atteindre 60 cm) faits de tubes de cuivre ou de polyéthylène haute densité. Le système a été contrôlé au cours de l'hiver 1988-1989, et sa performance s'est révélée excellente. Les résultats obtenus alors et notre expérience indiquent qu'il est possible de faire des économies substantielles sur les coûts initiaux d'installation. Il se peut en outre que ces systèmes horizontaux soient dans la plupart des cas plus économiques que les systèmes verticaux de PCCS.

CISTI / ICIST

3 1809 00257 9057

Spiral Ground Heat Exchangers for Heat Pump Applications

Otto J. Svec

Institute for Research in Construction
National Research Council of Canada
Ottawa, Ontario, K1A 0R6, Canada

ABSTRACT

This paper describes a novel horizontal ground heat exchange system used in an experimental Ground Source Heat Pump (GSHP) installation. The basic concept is to activate a large mass of soil by employing "large" (up to 60 cm) spiral heat exchangers made of copper and high density polyethylene tubing. The results of monitoring the system during the 1988/89 winter season demonstrate its excellent performance. In addition, these results together with our experience, indicate that large potential savings on initial installation costs are possible. Moreover, such horizontal systems may be more economical than vertical GSHP systems in most practical situations.

KEYWORDS

Heat pump, ground, heat exchanger, spiral

1) Introduction

The GSHP system is recognized as the most successful of all renewable energy technologies in most Northern European and North American countries. The GSHP's high initial cost is the only factor slowing down its wide-spread penetration into the marketplace. A large part of this cost, i.e. 30-40% (and in some cases even more), is associated with the installation of ground heat exchange systems.

The main objective of the research program at the Institute for Research in Construction, National Research Council Canada (IRC/NRC) has been to develop a highly efficient ground heat exchanger. The goal has been to reduce the required length of a ground collector through improved efficiency, and therefore to lower the overall cost of GSHPs. Efforts have been successful and the ground heat exchange technology developed in IRC/NRC is now ready to be transferred to the GSHP industry.

2) The NRC Ground Heat Exchanger

Research work at IRC/NRC, which progressed from laboratory studies, Ref. 1, through testing prototypes in the field, Refs. 2,3, and finally to a full scale testing of GSHP systems in two experimental houses, Ref. 4, resulted in a new ground heat exchanger design. Its main feature is the spiral shape of the heat exchanger itself and a straight tube return, Fig 1.

Fig. 1. Horizontal Spiral Ground Heat Exchanger
Installed In A Ditch

Such a heat exchanger can perform well in both vertical and horizontal configurations. In this paper, only the performance of the horizontal copper and plastic spiral heat exchangers is described. This technology has been developed to such a degree, particularly the plastic 60 cm (24") spiral, that it can be readily manufactured and used in commercial applications practically without modifications. The simplicity of its design and installation technique should make this ground heat collector technique superior to any other currently in use.

There are several key advantages of the spiral design:

- * the thermal interaction between the "IN" loop (spiral) and the "OUT" loop (the return pipe) is negligible;

- * the heat exchange surface is always at the outside boundaries of the ditch, so that the effective surface is a cylinder 60 cm (24") in diameter;
- * the spiral acts as a spring and thus can be stretched to any desired spacing, i.e. a designer can choose the heat extraction intensity;
- * it is very easy to install: all that is needed is to stretch the collapsed coil and then to backfill;
- * the geometry of the spiral is automatically assured by the coil itself;
- * the entire installation of the ground heat collector can be completed by only one person (plus the back-hoe operator);
- * both the copper and polyethylene spirals are strong enough to allow easy and effective backfilling (particularly with sand);
- * only one connection is needed at the end of the ditch.

The only disadvantage so far experienced, is the possibility of air collection at the top of the spiral loops. However, by using an oversized pump at the time of filling and carefully deaerating the system, this problem can be overcome.

3) Experimental Setup

In the fall of 1988 large horizontal copper and high density polyethylene spiral heat exchangers were installed as part of a 5.25 kW GSHP system. These spiral coils were fabricated specially for this project by copper and plastic tube manufacturers. There were no difficult problems encountered in the fabrication process. The specifications for these heat exchangers are as follows:

Table I. Specifications Of Heat Exchangers

Material	Tubing	Spiral Size	Spiral Pitch
Copper	2.2 cm (7/8")	60 cm (24")	12 cm (8")
Polyethylene	3.3 cm (1.31")	45 cm (18")	12 cm (8")

Three heat exchangers were installed: two copper spirals each in a 4.9 m (16') long ditch and one plastic spiral in a 9.8 m (32') long ditch. The total length, therefore, was 19.5 m (64') in terms of the ditch. This represents 1/10th or 1/6th of the standard design depending on one or two tubes in a ditch, respectively. All three heat exchangers were installed in a 1.8 m (6') deep ditch excavated in leda clay soil and backfilled up to the top of the spirals with sand, Fig. 1. A mixture of water/methanol was used as the heat carrying fluid. This system was heating a 90 m² experimental one

storey house, i.e. 90 m² on the main floor and the same area in the basement, during the 1988/89 winter season without any backup. The indoor temperature was kept constant at 22°C. The main objective of this experiment was to determine the heat extraction rates for these coils operating at subfreezing temperatures.

4) Monitoring Of System Performance

The determination of the system performance is based on monitoring the extracted energy from the ground, energy used to run the heat pump and the energy consumed by the circulation pump. In addition, the behavior of the system during individual cycles is being observed, as well as the ground thermal depletion and its recharging. The system has been monitored at approximately 15 second intervals during each running cycle. A computer program is initiated by the impulse from the thermostat as it demands heating or cooling. The inlet and outlet temperature of the circulating fluid (water/methanol) is measured at the distribution manifold in the basement of the house for each heat exchanger separately, and as well, for the system as a whole. There are two thermistors in each location. The overall accuracy of these sensors is $\pm 0.005^\circ\text{C}$. The accuracy of the fluid flow meters is about 1 - 2%.

After each cycle, readings are summarized and the average difference of the inlet and the outlet temperatures is computed. This information, together with fluid flow (accumulated volume), is used to calculate gained or dissipated energy by each ground loop, as well as by the entire system. Daily, weekly, and monthly energy balances are determined. In order to assess the overall performance of individual heat exchangers, the heat energy extraction or rejection per meter of the ditch is also calculated.

5) Results

The average daily outside air temperatures from December to April are shown in Fig. 2 for reference purposes. The data points represent daily average temperatures measured at 20 minute intervals.

The most significant result of this study is that by using large spiral heat exchangers, high rates of heat extraction, E_x , from the ground can be obtained, Table II.

Table II. Heat Extraction Rates (E_x) in Watts per meter of the ditch, Coefficient of Performance (COP) and water return temperatures (T_w), during 1988/89 winter season

Month	E_x Plastic	E_x Copper	E_x Copper	E_x System	COP	T_w
Dec.	140	170	165	158	2.55	-0.9
Jan.	130	155	155	148	2.45	-3.0
Feb.	120	145	145	137	2.40	-3.8
Mar.	125	153	155	144	2.35	-3.8
Apr.	125	170	160	152	2.35	-1.7

As expected, the copper spirals performed better than the plastic ones due to the higher thermal conductivity of the copper. It should be noted, however, that the contact (heat exchange) area between the tube and the soil was $7.0 \text{ cm}^2/\text{cm}$ for copper and $10.5 \text{ cm}^2/\text{cm}$ for plastic, i.e. 1.5:1.0 ratio in favor of plastic tube. The linear length of the tubes per meter of the ditch for copper and plastic spirals was approximately the same. Yet, because the copper spirals had larger outside diameter than the plastic spirals, i.e. 60 cm versus 45 cm, the former activated a larger soil mass. Therefore the comparison between these two spiral heat exchangers is based on three variables: material, (copper versus plastic), tube diameter (2.2 cm versus 3.34 cm) and spiral diameter (45 cm versus 60 cm), Table I. In spite of these differences, the comparison is realistic, since two practical designs based on considerations such as cost, manufacturing process, handling etc. are compared. Moreover, it is expected that the future design of either plastic or copper spiral heat exchangers will not significantly differ from those used in this project.

In summary, the significance of the results presented in Table II is two-fold:

- a) the heat extraction rates are very high and
- b) the difference between the heat extraction rates for copper and plastic spirals is not as large as expected.

Economic and practical considerations will determine whether copper or plastic spirals will be used in commercial installations. In the author's opinion, large (60 cm) spirals made from high density polyethylene tubing, 3.3 - 4.0 cm in outside diameter, will be the most practical choice.

Variations in heat extraction rates during the winter season are shown in Fig. 3. These results for the months of December, February and April represent typical behavior of the ground heat exchangers. The important aspect here is the magnitude of energy withdrawn from the ground.

Another set of data, presented in Fig. 4 shows temperature differences, dT , between the "IN" and the "OUT" tubes of all three heat exchangers during December, February and April. It can be observed that this difference (except in April) is largest for the plastic spiral. This result can be attributed to the fact that the length of the plastic spiral is twice as long as the copper one.

The overall dT for the entire ground heat exchange system during December, February and April is shown on Fig. 5. The significance of these results is that even though the absolute temperature of the circulating fluid decreases with increasing heating demand and ground thermal depletion, the dT remains constant - approximately 2°C .

The Coefficient of Performance (COP), see Table II, was lower than would be required in a commercial installation, but, considering the short length of the ground heat exchangers, the COP was still better than expected. The objective of this project was to determine the performance of prototypes of new ground heat exchangers, i.e. large horizontal spirals, and namely the rate of heat exchange during a normal winter operation. The objective was not to design an efficient GSHP system. In fact the ground heat collector was purposely underdesigned; therefore, assessment of COP should be understood from

Fig. 2. Average Daily Temperatures During 1988/89 Winter

Fig. 3 Variations In Heat Extraction Rates Of Individual Heat Exchangers During The Winter Season

Fig. 4 Fluid Temperature Difference Between The Inlet And Outlet For Individual Heat Exchangers

Fig. 5. Circulating Fluid Temperatures For The Ground Heat Exchange System As A Whole

this perspective. The COP is, however, very respectable for such a small ground heat exchange system. As mentioned above, the total length of the ground heat exchange system (in terms of required ditch) was only a fraction of what is currently being used by the GSHP industry.

As could be expected, the COP decreased with decreasing circulating fluid temperature, Table II. The decrease of the entering water/methanol temperature from 0°C at the beginning of December to -5.5°C in the middle of March, resulted in about a 10% decrease of COP. This is only a modest loss, one which might be lowered by optimizing the entire system.

6) Conclusion

Large diameter spiral horizontal copper and plastic heat exchangers have been developed, constructed and tested in a real field installation. No difficulties were encountered in the fabrication process and no problems were experienced in the installation. The installation process proved to be simple, fast and inexpensive. In fact, the entire ground heat exchange system using either copper or plastic spirals can be installed easily by only one person (plus an operator for the excavation machine).

Heat extraction results are very good. Due to the expected low cost of the heat exchangers, the simplicity of their installation, and their high performance, this new ground heat exchange technology will decrease the initial cost of GSHP's in general. It is expected that GSHP's utilizing these new ground heat exchangers will become competitive in the heating/cooling market.

This new technology (particularly the plastic spirals) is at the stage where it can be adopted easily by the GSHP industry. Manufacturers of plastic tubing have to be found, who are prepared to produce standard 60cm/3.34cm (24"/1.31") spiral/tubing coils. The initial response from a few manufacturers in Canada was positive; no major problems associated with the manufacturing process are expected.

REFERENCES

- Svec, O.J., L.E. Goodrich and J.H.L. Palmer (1983). Heat transfer characteristics of in-ground heat exchangers. *Energy Research*, Vol. 7, p.265-278. (NRCC 22674)
- Svec, O.J. (1985). Potential for improvement between ground and heat pump energy exchange. *Proceedings, Second Workshop on Solar Assisted Heat Pumps with Ground Coupled Storage*, Vienna, Austria, July 1985, p 431-440. (NRCC 27413)
- Svec, O.J. and Palmer J.H.L. (1989). Performance of a spiral ground heat-exchanger for heat pump application. *Int. Journal of Energy Research*, Vol 13, p. 503-510..
- Svec, O.J. (1988). Spiral heat exchangers - Demonstration of a new ground source heat pump technology. *Proceedings, Jigastock 88*, 18-21 October 1988, Versailles, France, Vol. 2, p.583-587.

ACKNOWLEDGEMENTS

The author wishes to express his gratitude to Dr. J.H.L. Palmer of IRC/NRC for many inspiring discussions, to Messrs. D. Eldred and D. MacMillan for their excellent technical assistance and to Mr. Mike Wiggin of the Department of Energy Mines and Resources, CANMET Laboratories for his encouragement and the EMR continuous support.

This paper is being distributed in reprint form by the Institute for Research in Construction. A list of building practice and research publications available from the Institute may be obtained by writing to Publications Section, Institute for Research in Construction, National Research Council of Canada, Ottawa, Ontario, K1A 0R6.

Ce document est distribué sous forme de tiré-à-part par l'Institut de recherche en construction. On peut obtenir une liste des publications de l'Institut portant sur les techniques ou les recherches en matière de bâtiment en écrivant à la Section des publications, Institut de recherche en construction, Conseil national de recherches du Canada, Ottawa (Ontario), K1A 0R6.