

## NRC Publications Archive Archives des publications du CNRC

**Airflow tests in a model of no. 2 cell, engine laboratory, N.R.C.**  
Fowler, H. S.

For the publisher's version, please access the DOI link below./ Pour consulter la version de l'éditeur, utilisez le lien DOI ci-dessous.

### **Publisher's version / Version de l'éditeur:**

<https://doi.org/10.4224/40003964>

*Laboratory Memorandum (National Research Council Canada. Division of Mechanical Engineering. Engine Laboratory); no. NRC-ENG-13, 1959-09-02*

### **NRC Publications Archive Record / Notice des Archives des publications du CNRC :**

<https://nrc-publications.canada.ca/eng/view/object/?id=2281defa-53d3-46a4-b5ff-3e242dd4ba48>

<https://publications-cnrc.canada.ca/fra/voir/objet/?id=2281defa-53d3-46a4-b5ff-3e242dd4ba48>

Access and use of this website and the material on it are subject to the Terms and Conditions set forth at

<https://nrc-publications.canada.ca/eng/copyright>

READ THESE TERMS AND CONDITIONS CAREFULLY BEFORE USING THIS WEBSITE.

L'accès à ce site Web et l'utilisation de son contenu sont assujettis aux conditions présentées dans le site

<https://publications-cnrc.canada.ca/fra/droits>

LISEZ CES CONDITIONS ATTENTIVEMENT AVANT D'UTILISER CE SITE WEB.

**Questions?** Contact the NRC Publications Archive team at

PublicationsArchive-ArchivesPublications@nrc-cnrc.gc.ca. If you wish to email the authors directly, please see the first page of the publication for their contact information.

**Vous avez des questions?** Nous pouvons vous aider. Pour communiquer directement avec un auteur, consultez la première page de la revue dans laquelle son article a été publié afin de trouver ses coordonnées. Si vous n'arrivez pas à les repérer, communiquez avec nous à PublicationsArchive-ArchivesPublications@nrc-cnrc.gc.ca.

L.O. 13387A

FILE CM2-17-13T-6

PREPARED BY H.S.  
Fowler  
E.P.

CHECKED BY Cockshutt

NATIONAL RESEARCH COUNCIL  
DIVISION OF MECHANICAL ENGINEERING  
OTTAWA, CANADA  
LABORATORY MEMORANDUM

SECTION ENGINE LABORATORY

NO. NRC-ENG-13

PAGE 1 OF 3

COPY NO. 28

DATE 2 Sept., 1959

SECURITY CLASSIFICATION OPEN

SUBJECT AIRFLOW TESTS IN A MODEL OF No. 2 CELL, ENGINE  
LABORATORY, N.R.C.

PREPARED BY H.S. Fowler.

ISSUED TO

THIS MEMORANDUM IS ISSUED TO FURNISH INFORMATION  
IN ADVANCE OF A REPORT. IT IS PRELIMINARY IN CHARACTER,  
HAS NOT RECEIVED THE CAREFUL EDITING OF A REPORT, AND  
IS SUBJECT TO REVIEW.

NATIONAL RESEARCH COUNCIL  
DIVISION OF MECHANICAL ENGINEERING  
LABORATORY MEMORANDUM

-2-

AIRFLOW TESTS IN A MODEL OF No. 2 CELL,  
ENGINE LABORATORY,  
N.R.C.

INTRODUCTION

It is intended to test a VTO turbine rig in No. 2 cell of the Engine Laboratory. This unit consists of a tip turbine on the periphery of the VTO fan. In the turbine test rig the fan will be used as a brake to absorb the power of the turbine, and possibly to measure it. The air flow into the fan must therefore be uniform and steady, and the exit airflow must be unobstructed and not give rise to eddying and pressure fluctuations in the test cell. Since the air flows in the cell would be large (400 lbs/sec estimated maximum cell throughput), and there were certain possible obstructions in the cell, it was considered advisable to run airflow tests on a model of the cell. Experience has shown that satisfactory correlation with full-scale observations is obtained with models of 1" = 1' scale. A plywood model with one "Lucite" wall was therefore built to this scale, and a dummy fan unit, incorporating an external compressed air supply and an ejector pump, was mounted in it. Tests on possible fan positions, and on various possible modifications to the cell, were then made, plotting the air flow by means of cotton tails on a probe and by injecting quantities of dust. These tests showed that relatively simple modifications would provide a satisfactory flow pattern in the cell.

DESCRIPTION OF MODEL

The model test cell (See Fig. 1) was built to a scale of 1" = 1', using 1" and 1/2" plywood, with the southeast wall of 1/4" Lucite. The model of the turbine and fan unit was built from brass and copper tube to the same scale. The fan unit could be moved up and down in the cell. The front-end half-wall of the cell was removable, and, while the earlier tests were made with an open back end, the exit stack and various arrangements of exit-end curtain wall were fitted for later tests.

DESCRIPTION OF TESTS

Tests were carried out on 12 configurations, and a chart of the air flow in each case is given. In order to obtain comparable conditions in each case, the ejector air supply pressure was always set at 10 psig. However, tests over a range

NATIONAL RESEARCH COUNCIL  
DIVISION OF MECHANICAL ENGINEERING  
LABORATORY MEMORANDUM

-3-

from 5 to 50 psig. showed no changes in airflow pattern.


It was obviously desirable to modify the cell as little as possible; so the tests took the present arrangement as their basis and introduced modifications one by one, to determine their effects (See Table I and Figs. 2 to 13). Brief notes accompany each airflow chart, describing the modification tested and the results of this modification.

It becomes clear from the charts that the best configuration is that incorporating a new inlet wall, with a 9-foot-square window in it, and an open back end leading straight into the exit stack.



However, considering the amount of work required to modify the inlet wall to this standard, tests also show that the use of the present inlet wall, with the doors closed, will provide quite an acceptable air flow. This is reasonably symmetrical and stable. It is definitely necessary, however, to remove all the sheet covering of the exit-end curtain wall, although the girder framework may be allowed to remain, if so desired. The existing elbow in the stack increases the recirculation if left in position, although it protects the back wall from direct blast. However, to minimize the circulation of exhaust gas into the fan intake, it should be moved to the side of the stack, where it causes little disturbance.

#### CONCLUSIONS

Various configurations of Cell 2, with a dummy VTO fan installation, have been tested. While not giving the best possible air flow, it has been shown that a readily available configuration will give a satisfactory air flow for testing the turbofan unit. The inlet wall is left in its present condition, with its doors closed. The turbofan unit is mounted at the rear edge of the shaft from Cell 3, with its  $Q_L$  5'0" above the floor. The exit-end curtain wall is removed, the duct elbow is moved to one side of the stack. It is thought advisable to protect the sloping rear wall of the stack for some 12' up, as this area will be heavily scrubbed by the exhaust. This will not be too hot, but will have an erosive effect.



AIRFLOW MODEL OF N° 2 CELL.  
ENGINE LABORATORY.



TEST No 1



CONFIGURATION.  
 UNMODIFIED INLET CURTAIN WALL,  
 DOOR OPEN, FAN 5'-0" UP FROM  
 FLOOR, EXIT END OPEN, NO STACK.

PLAN.

REMARKS.  
 CROSS FLOW NEAR INTAKE, DUE TO OPEN DOOR.  
 SOME REVERSE FLOW, NOTABLY ABOVE ENGINE & ON  
 CONTROL-ROOM SIDE.  
 FLOW STABLE NEAR INTAKE & EXHAUST.

THIS PART FITTED ONLY FOR TESTS  
9 AND 10

FIG 2





TEST N° 2

CONFIGURATION.

UNMODIFIED INLET CURTAIN WALL,  
 DOOR CLOSED, FAN 5'-0" UP,  
 EXIT END OPEN, NO STACK.

REMARKS.

AS IN TEST 1, BUT CROSS FLOW AT FAN INLET VIRTUALLY  
 ELIMINATED. REVERSE FLOW STILL MAINLY ON  
 CONTROL-ROOM SIDE.



TEST N° 3.



CONFIGURATION.

UNMODIFIED INLET CURTAIN WALL  
 DOOR CLOSED, FAN 9'-0" UP  
 EXIT END OPEN, NO STACK.

REMARKS.

FAN INLET FLOW VERY ASSYMETRIC, & VERY UNSTABLE.  
 CONSIDERABLE REVERSE FLOW ALL ROUND CELL.

FIG 4.





TEST N° 4.  
CONFIGURATION.

FRONT CURTAIN WALL REMOVED.  
 FAN 5'-0" UP.

REMARKS.

FLOW SWEEPS DOWN, HITS FLOOR, AND BOUNCES UP  
 INTO FAN INTAKE, IN VERY ASYMMETRIC MANNER.

Fig. 5.





TEST NO. 5.

CONFIGURATION.

INLET WALL REPLACED BY WALL  
WITH 9'-0" SQUARE WINDOW WITH  
1'-0" RAD. LIP ALL ROUND.  
EXIT END OPEN, NO STACK.

REMARKS.

FLOW VERY STABLE & SYMMETRICAL AT INLET.  
REVERSE FLOW REDUCED.





TEST No. 6.  
CONFIGURATION.

AS IN TEST 5, BUT WITH CURTAIN WALL  
ACROSS MIDDLE OF CELL  
EXIT END OPEN, NO STAIR.

REMARKS.

REDUCED ALARMY LIGHT REVERSE FLOW,  
BUT NOT COMPLETELY.



TEST N° 7.



CONFIGURATION.

TOP HALF INLET WALL ONLY

NO EXIT END, WALL, NO STACK

REMARKS.

INLET END DOWN-FLOW WORSE THAN WITH ANY PREVIOUS CONFIGURATION.



TEST No. 8.

CONFIGURATION.



INLET WALL, WITH 9' SQ. WINDOW.

EXIT WALL, WITH 9' SQ. WINDOW.

NO EXIT STACK.

REMARKS.

REVERSE FLOW INCREASED,  
PARTICULARLY AT TOP OF FAN.





TEST N° 9.  
CONFIGURATION.

AS RUN 8, BUT WITH EXITSTACK

REMARKS.

FLOW IN CELL HARDLY MODIFIED. SLIGHTLY MORE REVERSE FLOW.  
FLOW IN STACK REASONABLE.

FIG. 10.







TEST No. 10.

CONFIGURATION.

UNMODIFIED INLET WALL, DOOR CLOSED,  
 NO EXIT WALL, STACK PRESENT,  
 FAN 5'-0" UP.

REMARKS.

VERY SLIGHT INCREASE OF REVERSE FLOW  
 AT REAR OF CELL.  
 APPEARS A PRACTICAL ARRANGEMENT.



TEST N° 11.

CONFIGURATION

EXIT ELBOW AT SIDE OF CELL.

REMARKS

HAS LITTLE INFLUENCE ON FLOW.

TEST N° 12.

CONFIGURATION.

EXIT ELBOW IN NORMAL POSITION.

REMARKS.

PROTECTS REAR WALL, BUT CAUSES INCREASED RECIRCULATION.

FIG. 12.

FIG. 13.

## TEST SUMMARY.

TEST No.	INLET CURTAIN WALL.	FAN POSITION.	CENTRE CURTAIN WALL.	EXIT CURTAIN WALL.	EXHAUST END.
1.	UNMODIFIED, DOOR OPEN.	☉ 5'-0" ABOVE FLOOR	NONE.	NONE.	OPEN. NO STACK ON MODEL.
2.	UNMODIFIED, DOOR CLOSED.	"	"	"	"
3.	"	☉ 9'-0" ABOVE FLOOR.	"	"	"
4.	ENTIRELY REMOVED.	☉ 5'-0" ABOVE FLOOR	"	"	"
5.	CURTAIN FULLY BLOCKING END, WITH 9'x9' OPENING ON FAUC, WITH 1" RAD. LIP.	"	"	"	"
6.	"	"	COMPLETE CURTAIN WALL IN PLANE OF FAN	"	"
7.	CURTAIN DOWN FROM ROOF, TO 11' ABOVE FLOOR, WITH 1" RAD LIP, RIGHT ACROSS CELL	"	NONE.	"	"
8.	CURTAIN WITH 9'x9' OPENING AS IN ⑤ ABOVE	"	"	CURTAIN RIGHT ACROSS EXIT END, WITH 9'x9' OPENING ON FAUC, NO LIP.	"
9.	AS IN ② ABOVE UNMODIFIED ORIGINAL INLET WALL, DOOR CLOSED.	"	"	"	MODEL OF STACK IN POSITION
10.	"	"	"	NONE.	"
11.	"	"	"	"	" , ELBOW IN POSITION AT SIDE
12.	"	"	"	"	" , ELBOW IN POSITION ON ☉.

TABLE I.